

# Mounting Release

State: 17.10.2016

## DICTATOR V 1600F Door Check on Fire Protection Doors

The following table lists all manufacturers and their fire protection doors on which the DICTATOR V 1600F door check may be mounted

- because it is part of the door approval
- or because we have a manufacturer's declaration for using the V 1600F door check on the respective door.

Manufacturer	Type of door	Closing device		Approval	Manufacturer's declaration
		Spring hinge	Overhead door closer		
<b>Domoferm</b>	all	x	x		06 February 2015
<b>Hörmann</b>	H8-5		x	Z-6.20-2063 state 05.03.2015	27 April 2015
	Quadro		x	Z-6.20-1852 state 04.03.2011	27 April 2015
	H3, H3-RS* <sup>1</sup>	x	x	Z-6.20-1929 state 05.11.2014	31 July 2015
	H3D, H3D-RS* <sup>1</sup>	x	x	Z-6.20-1974 state 21.03.2013	31 July 2015
	H16, H16-RS* <sup>1</sup>	x	x	Z-6.20-2010 state 02.06.2014	31 July 2015
	H6, H6-RS* <sup>1</sup>	x	x	Z-6.20-2047 state 11.02.2015	31 July 2015
	H3 OD, H3 OD-RS* <sup>1</sup>	x	x	Z-6.20-2203 state 16.12.2014	31 July 2015
	H16 OD, H16 OD-RS* <sup>1</sup>	x	x	Z-6.20-2234 state 19.02.2015	31 July 2015
	H3	x	x	Z-6.21-2186 state 25.04.2013	31 July 2015
	HE 311, T 30-1-(RS)-FSA* <sup>2</sup>		x	Z-6.20-1898 state 02.10.2016	11 October 2016
	HE 321, T 30-2-(RS)-FSA* <sup>2</sup>		x	Z-6.20-1898 state 02.10.2016	11 October 2016
	HE 312, T 30-1-FSA* <sup>2</sup> (exterior use)		x	Z-6.21-2239 state 17.01.2015	11 October 2016
	HE 322, T 30-2-FSA* <sup>2</sup> (exterior use)		x	Z-6.21-2239 state 17.01.2015	11 October 2016
	HE 611, T 60-1-(RS)-FSA* <sup>2</sup>		x	Z-6.20-1839 state 14.01.2015	11 October 2016

Manufacturer	Type of door	Closing device		Approval	Manufacturer's declaration
		Spring hinge	Overhead door closer		
<b>Hörmann</b>	HE 621, T 60-2-(RS)-FSA* <sup>2</sup>		x	Z-6.20-1839 state 14.01.2015	11 October 2016
	HE 911, T 90-1-(RS)-FSA* <sup>2</sup>		x	Z-6.20-1966 state 21.12.2012	11 October 2016
	HE 921, T 90-2-(RS)-FSA* <sup>2</sup>		x	Z-6.20-1966 state 21.12.2012	11 October 2016
	A/RS 150, RS-1-door* <sup>2</sup>		x	P-3545/787/14-MPA BS state 01.04.2014	11 October 2016
	A/RS 250, RS-2-door* <sup>2</sup>		x	P-3545/787/14-MPA BS state 01.04.2014	11 October 2016
	A/RS 100, RS-1-door* <sup>2</sup>		x	P-3609/851/14-MPA BS state 01.07.2014	11 October 2016
	A/RS 200, RS-2-door* <sup>2</sup>		x	P-3609/851/14-MPA BS state 01.07.2014	11 October 2016
<b>Novoform Riexinger</b>	„NovoPorta Premio“ T 30-1-FSA	x	x		24 November 2014
	„NovoPorta Premio“ T 30-1-RS-FSA		x		24 November 2014
<b>DMW Schwarze</b>	Schwarze-S20 Schwarze-S1 Schwarze-FE	x	x		12 November 2015
<b>Schüco</b>	ADS 80 FR 30* <sup>3</sup>		x	Z-6.20-1888 state 09.02.2015	
<b>Teckentrup</b>	all	x	x		10 October 2014

\*<sup>1</sup> max. modular dimension 1250 x 2500 mm. In the case of doors with two leafs and all other not mentioned fire doors, please contact the DICTATOR technical customer service..

\*<sup>2</sup> max. modular dimension 1250 x 2500 mm, max. weight of door leaf 200 kg. In the case of doors with two leafs and all other not mentioned fire doors, please contact the DICTATOR technical customer service.

\*<sup>3</sup> In the case of doors with two leafs and all other not mentioned fire doors, please contact the DICTATOR technical customer service.

## You have questions?

We provide individual advice.  
Just contact us!